

# **EA** networks

*connecting our community*

## EA NETWORKS ASSET MANAGEMENT PLAN UPDATE 2022-32



## **ASSET MANAGEMENT PLAN UPDATE FOR EA NETWORKS' ELECTRICITY NETWORK**

Planning Period: 1 April 2022 to 31 March 2032  
Disclosure Year: 2022-23  
Disclosure Date: 31 March 2022  
Approved by Board: 30 March 2022

EA Networks  
Private Bag 802  
Ashburton 7740

Website: <http://www.eanetworks.co.nz>  
Telephone: (03) 3079800  
Facsimile: (03) 3079801

© Copyright: EA Networks. 2022

As of November 2012, EA Networks is the trading name of Electricity Ashburton Limited. References to EA Networks in this document denote Electricity Ashburton Limited.

The owner and custodian of this document is the Network Division of EA Networks, Ashburton. All comments, queries and suggestions should be forwarded to the Network Manager.

# CONTENTS

	Page
<b>ASSET MANAGEMENT PLAN UPDATE</b>	<b>5</b>
1 Scope of this Document	5
2 Changes to Network Development Plans	5
3 Changes to Lifecycle Asset Management Plans	8
4 Reasons for Material Changes to Disclosure Schedules 11a and 11b	8
5 Changes to Asset Management Practices	11
6 Disclosure Schedules 11a, 11b, 12a, 12b, 12c, 12d, 14a, and 17	11
Schedule 11a Report on Forecast Capital Expenditure	9
Schedule 11b Report on Forecast Operational Expenditure	11
Schedule 12a Report on Asset Condition	12
Schedule 12b Report on Forecast Capacity	13
Schedule 12c Report on Forecast Network Demand	14
Schedule 12d Report on Forecast Interruptions and Duration	15
Schedule 14a Mandatory Explanatory Notes on Forecast Information	16
Schedule 17 Certification for Year-beginning Disclosures	17

## **Liability Disclaimer**

---

This document has been produced and disclosed in accordance with the disclosure requirements under subpart 9 of Part 4 of the Commerce Act 1986 (Electricity Information Disclosure Determination 2012).

Any information contained in this document is based on information available at the time of preparation. Numerous assumptions have been made to allow future resource requirements to be assessed. These assumptions may prove to be incorrect or inaccurate and consequently any of the future actions that are identified in this document may not occur.

People use information contained in this document at their own risk. EA Networks will not be liable to compensate any person for loss, injury or damage resulting from the use of the contents of this document.

If any person wishes to take any action based upon the content of this document, they should contact EA Networks for advice and confirmation of all relevant details before acting.

# ASSET MANAGEMENT PLAN UPDATE

## 1 *Scope of this Document*

In certain disclosure years, the Commerce Commission's Electricity Information Disclosure Determination 2012 allows a distribution lines company to prepare and disclose an Asset Management Plan Update rather than a full Asset Management Plan. The 31 March 2022 disclosure date is one of these occasions when an update is permitted. EA Networks have chosen to issue an Asset Management Plan Update for the 31 March 2022 disclosure date.

This document is the EA Networks 2022-2032 electricity network Asset Management Plan Update. It presumes that the reader has examined the EA Networks 2021-31 Asset Management Plan and it provides incremental information from that plan.

The layout of the document headings follow clause 2.6.4 of the Disclosure Determination.

## 2 *Changes to Network Development Plans*

### Subtransmission System

The previous AMP/disclosure forecast that the Montalto 66kV zone substation would be built in the 2029-30 financial year. Without load growth in the Montalto area, the need for this development continues to be uncertain and it has been rescheduled for the 2030-2031 financial year. The associated projects provide:

- a 66kV line to/from Mt Somers to Montalto 66kV zone substation (~\$1.2M),
- a 66kV line to/from Carew to Montalto zone substation (~\$3.5M), and
- 66kV line bays in Mt Somers and Carew zone substations (~\$450k).

These related projects have all been delayed by a further year. These load-driven projects are looking less and less likely to proceed.

Rural load growth remains largely static. The possibility of gravity pressurised piped irrigation development, which could not only postpone additional load but remove existing load, have made the situation quite uncertain. Nutrient discharge restrictions by ECAN have effectively suppressed new irrigation development in this area and other areas.

The 11kV distribution network in the Montalto area is under pressure from existing load and, if Montalto 33kV substation is unavailable for some reason, back-feeding into the area causes unacceptably low voltages. It is intended to convert the 11kV distribution system to 22kV in the Montalto area. This will allow the Montalto 33kV substation to be removed, all load to be supplied from Mt Somers substation, and multiple 22kV back-feed options to be available.

The proposed 66kV line between Hackthorne and Lauriston (~\$3.7M) is driven by a combination of load growth in the Methven area and additional security to Lauriston, Methven, Hackthorne and Mt Somers during 66kV line outages. Summer load has not increased in the Methven area but could still do so. It has been decided to delay the construction of the Hackthorne-Lauriston 66kV line and associated works to coincide with a second GXP (2030). This new line would provide a ring of 66kV from the new GXP. The immediate security concern about Lauriston and Overdale Zone Substations has been resolved with a short (3km) new 66kV circuit from Lauriston Zone Substation to the Overdale-Methven 66kV line (a location now referred to as "Lauriston T"). This 66kV line has been delayed by Line Road's realignment uncertainty (Ashburton District Council – delayed by several years) but is largely finished and will now be completed in 2022-23. The associated 66kV line bay at Lauriston has already been completed.

Decarbonisation efforts largely impact coal users within Mid-Canterbury. These include food processing, schools, and the hospital. All of these sectors are actively looking at or progressing the elimination of coal. At this stage, supplying the proposed additional decarbonisation loads appears to be possible.

Large solar farm developers have approached EA Networks with the notion of investigating connecting solar photovoltaic generation in the order of tens of MW. The summer irrigation load profile provides a

reasonably synergistic relationship with this type of generation. The distance from the Transpower grid exit point and the 66 kV circuit thermal rating will dictate the ability of the 66 kV network to accommodate a large-scale solar farm.

## Zone Substations

As mentioned above, the Montalto 66 kV zone substation (~\$2M) has been rescheduled later than previously disclosed (now 2030-31). It is entirely possible that further delays may occur if sufficient irrigation or other load/generation does not eventuate.

It is intended to decommission the existing Montalto 33/11 kV Zone Substation as well as converting the Montalto Hydro Power Station to 22 kV (from 33 kV) in 2025. The surrounding 11 kV distribution network will be progressively converted to 22 kV. This will ultimately lead to the Montalto 33/11 kV substation becoming redundant. Should the load increase sufficiently, it will trigger development of the Montalto 66/22 kV Zone Substation on a new site (already secured).

The Fairton 33/11 kV Zone Substation has been dismantled, with only the building (privately owned) and some minor non-operational switchgear remaining. Talley's have purchased the ex-Silver Fern Farms Fairton site and intend to develop it over the coming years. This load will be served from the adjacent Fairton 66/22/11 kV Zone Substation.

With the prospect of demand control no longer being incentivised by Transpower's pricing, funds have been allocated for investment in an alternative load-control signalling technology that could offer much more granular control and near-real-time power system data gathering capabilities. Research and trials into viable alternatives to ripple technology are underway. Should the alternatives not prove to be viable, the new 66 kV ripple plant could be reinstated using the same funds. The existing 33 kV ripple plant at Elgin has been scheduled for replacement in 2026. This plant would be a hot standby for the new 66 kV plant, should that be installed. If an alternative signalling technology is introduced, the 33 kV ripple plant replacement funds may be allocated to expand that alternative system.

## Distribution Network

The delay in Montalto zone substation (see above) causes downstream delays in a distribution project - the additional overhead and underground 22 kV network needed to integrate the Montalto 66 kV zone substation into the distribution network (~\$760k). This project has been postponed, coinciding with Montalto zone substation construction. The conversion of the Montalto Hydro station to 22 kV (from 33 kV) will still proceed as planned (~\$270k), as the 33 kV circuit connecting it will be converted to 22 kV.

The urban underground conversion programme is documented (project by project) by ranking pole condition assessments to determine appropriate project timing. The plan now contains projects that should remove every urban distribution (22 kV, 11 kV, or LV) power pole before 2029. The average annual cost of this programme is about \$2M and is scheduled to end by 2030.

The urban underground conversion programme has been ambitious. Each year a reducing amount of the work has spilled over to the following year. There is a need to carefully manage the aged urban overhead line assets that the underground conversion programme replaces. Each conversion project (and the poles within it) will be carefully assessed and monitored to determine a strict priority to minimise the risk of failure. Where that risk is seen to be too high, mitigation measures will be introduced to reduce risk to an acceptable level.

It is anticipated that urban residential growth will continue to rise. This will be both in the number of new subdivisions and the likelihood of EV (electric vehicle) charging becoming more common. Provided EV charging is off-peak, it is not anticipated to cause any noteworthy issues during the planning period.


The rural 11 kV to 22 kV conversion programme is fully documented. By 2028, very little rural 11 kV network should remain. The order of conversion may change as the priority for capacity and/or security is reassessed. There is no provision for the 22 kV conversion programme in 2029. The average annual cost of this programme is ~\$350k in lines and ~\$1M in distribution transformers and is scheduled to end by 2029.

The overhead distribution line rebuilding programme has two/three years of specific projects documented based upon pole condition inspections. Data has been captured for additional years but has yet to be fully

assessed for inclusion as specific projects. This will occur in future plans. The effect of this is to reduce the large unscheduled Replacement and Renewal programme for the first two/three years. The average annual cost of this programme is about \$2.5M and is ongoing.

Beyond the scheduled overhead rebuild projects, the allowance for rebuilding is fixed until 2026. It is then increased by 10% per annum for three years, as the impact of the aging pole population impacts condition-based rebuilding. Additional inspection, analysis, and assessment will take place to refine this forecast. The diagram below illustrates the issue (note that the poles over 50 years old are predominantly urban poles awaiting removal once underground conversion takes place).

Untreated hardwood pole lines can be expected to last between 40 and 50 years. Some of the “second growth” hardwood poles supplied during the 1980s are showing signs of premature decay. Not all poles are affected, and future pole inspections will reveal if the issue will cause a shift in rebuild cost timing. The use of concrete and treated softwood poles during the 1980s and 1990s will dampen the rebuild requirements as they have a longer life than the untreated hardwood poles. During the late 1990s and beyond, the hardwood poles used were treated with preservative compounds that should increase their useful life beyond 40-50 years.



The chart above shows that approximately 2 300 poles are currently being installed every 5 years (460 poles per annum). If the average pole life is 45 years and there are 28 000 poles, then the long-run average pole replacement rate needs to be about 3 100 poles every five years (620 poles per annum). In about 15-20 years, an increased need for pole replacements will begin to occur, and that might peak at 50-60% more than current rates. This can be managed with careful consideration of pole types, risk, and individual pole condition, but adequate construction resourcing will also be important.

The Ashburton township core 11 kV network programme is documented to provide a sequence of specific projects. The core 11 kV network programme aims to significantly increase capacity and reduce the count of consumers per urban 11 kV feeder. Delays in switchgear approval and site procurement have caused programme postponement by one year. The first two network centres are now largely complete and further duct, cable, and site development is progressing. This programme has an average annual cost of \$650k and is scheduled to end by 2032.

## Other Project and Programmes

Modern protection relays are based upon microprocessors and microelectronics. These devices have expected reliable lives of less than 30 years. Most relay manufacturers have said that 20-year-old devices

are approaching the onset of unreliability and the limit of supportability with software. A programme of progressive 20-year-old relay replacement is in place to ensure in-service relay failures are a rare event. This programme has an average annual cost of about \$70k.

The New/Smart Technology programme incorporates projects that are associated with either solar PV, grid-connected batteries, electric vehicle charging, or general contingencies for unknown assets. The total expenditure is similar to the discrete projects. The programme starts in 2026 and is shown until the end of the planning period. The average annual cost is ~\$2M. A future plan will create specific projects to identify the work.

The Distribution Automation programme formalises a myriad of small projects. This retrospective automation programme runs from 2023 to 2025. By 2025 it is anticipated that most devices that can be remote controlled, will be. When appropriate, new equipment will be automated as part of the project creating the asset. The average annual cost of this programme is about \$300k.

The recently commissioned ADMS (Advanced Distribution Management System), of which SCADA is only one aspect, will be progressively enhanced over time to provide additional features. The ADMS has the potential to improve both reliability and customer responsiveness.

Corporate IT systems continue to develop, and an allowance has been made for ongoing improvements and integration.

### **3 Changes to Lifecycle Asset Management Plans**

The work order management / asset management system provides some facilities surrounding asset lifecycles. The inspection and testing of certain assets have been scheduled in the system. As the system matures and becomes better populated, the routine aspects of maintenance work will become more process driven.

There have been no material changes to the methodologies applied to lifecycle management plans during the last year. The previously manual process has now become more automated in some cases.

The identification of specific projects to replace end of life overhead lines (with either rebuilt overhead lines or underground cables) provides a clearer picture of future expenditure and resource requirements. This assessment work will continue to expand and gather condition data over time.

An external review of the risk and asset management processes in place at EA Networks is underway. Once this review has been completed, the beneficial action points will be adopted for implementation. The AMP will also be externally formally reviewed for completeness and to identify specific areas for improvement after considering any proposed changes to current asset management processes.

### **4 Reasons for Material Changes to Disclosure Schedules 11a and 11b**


There are only minor timing changes to the disclosure schedules which are generally caused by delays in projects as a consequence of COVID-19 or other external factors.

#### **Forecast Capital Expenditure – Schedule 11a**

With the exception of 2023 and 2024, the forecast overall capital expenditure is similar to the previous disclosure for the same year. Towards the end of the planning period, project timing has changed.

The graph below shows that the expenditure predicted in the 2022-32 plan is close to the 2021-31 plan for the 2024-32 period. The key difference is at the beginning of the planning period (2023-24). This difference is caused by several larger projects being incomplete in 2021-22, many new residential subdivisions (partly offset by capital contributions), and some unscheduled IT development. At the end of the planning period, a group of projects that are less certain are essentially pinned to the end of the planning horizon and have been delayed by a year.





Note that the costs are shown in 2022-23 dollars, exclude CPI adjustment, and include capitalised labour. The disclosure schedules at the end of the document include inflation adjusted cashflows.

The 2021-22 year is likely to have some carry-over into the 2022-23 year. This could be up to \$4M. The reasons for this include:

- Flooding event causing widespread farm and road damage which caused reprioritisation of civil contractors used for underground conversion work.
- COVID-19 interruptions decreasing efficiency and productivity.
- An unexpected resource issue caused a 33% reduction in underground conversion design throughput in the latter half of the year. This has now been addressed with the engagement of an external design resource (ongoing).
- The Ashburton 11 kV Core Network programme was partly delayed because of switchgear approval delays and site selection difficulties.
- State highway underground conversion was delayed due to uncertainty of the Waka Kotahi contribution timing.

A decision has been made to delay the rest of the Ashburton 11 kV Core Network programme by one year. This has lessened the impact of carry-overs on the 2022-23 year expenditure.

The unscheduled overhead line rebuild cost pool has been increased from the middle of the planning period to accommodate the pole age profile and anticipated gradual increase in overhead line rebuild rate.

The 10-year planning periods covered by the 2021-31 and 2022-32 plans have capital expenditure forecasts in them. A comparison of the forecasts shows the following:

Years	2021-31 Plan	2022-32 Plan
2022-32 (10y)	130.0M	129.4M
2023-31 (9y)	114.4M	119.2M

The overall (10y) comparison shows that, as predicted, the cumulative forecast is decreasing and will continue to do so (the net expenditure shows a larger downward trend).

The overlapping period (9y) has a variation between the two plans of about +\$4.8M out of a total of about


\$129M. This represents approximately +3.7%. There are several reasons for this variation:

- Some project costs have been reassessed and this has caused a small increase in costs.
- Some project work from 2021-22 is incomplete or has been delayed. A portion of this expenditure work has been allowed for in the 2022-23 year.
- New non-network software expenditure has been identified.
- Significant quantities of residential subdivision proposals have been newly revealed for 2022-23.

There is the prospect of one or more large solar farm connections to EA Networks' system that have not been included in the schedule. The prospects are still not definite, and consequently no allowance has been made. Should one or more of the prospects become a commitment, it is likely to progress very quickly and cause increased expenditure, which would be offset by a 100% capital contribution.

## Forecast Operational Expenditure – Schedule 11b

The overall operational expenditure forecast is significantly higher than the previous (2021 AMP) forecast. The future forecasts show a step rise in both categories of non-network expenditure. There are smaller rises in network expenditure.



Note that the costs are shown in 2022-23 dollars and exclude CPI adjustment. The disclosure schedules at the end of the document include inflation adjusted cashflows.

### Business Support

Several key drivers have increased the forecast Business Support cost from the historical predictions:

(a) Additional staff being employed to accommodate:

- the base workload,
- HR support,
- additional processes and systems which require support,
- changing the pool of skills available for implementing and maintaining new technologies.

- (b) Wage/salary inflation accompanying CPI.
- (c) Software licensing and security costs continue to increase significantly, above those anticipated in previous plans, exacerbated by the need for remote working.
- (d) Business assurance and R&D projects are proposed to explore better network and non-network performance.
- (e) Various unscheduled COVID-19 costs that are potentially ongoing.

### **System Operations and Network Support**

Similar drivers to Business Support have caused increases in forecast System Operations and Network Support:

1. Additional staff costs will also be incurred for similar reasons to those identified for Business Support.
2. Software licensing costs have increased well above those anticipated in previous plans.

### **Other Categories**

The direct asset categories have increased caused by labour costs reflecting the CPI, as well as proposed changes in tree management processes.

The AMP forecast has been prepared using ABAA accounting standards.

## ***5 Changes to Asset Management Practices***

There have been no material changes to asset management practices during the last year that would affect the disclosure of Schedule 13 contents.

As mentioned in section 3 above, a work order management / asset management system is now in place. This system is maturing but will take some time to change the methodologies used to manage the electricity assets. A future AMP will detail any material changes that are planned or occur.

The external review of risk and asset management processes currently underway may result in changes to asset management practices, and this will be documented in the next full plan.

## ***6 Disclosure Schedules 11a, 11b, 12a, 12b, 12c, 12d, 14a and 17***

EA Networks have chosen not to disclose Schedule 13 as is permitted in the Disclosure Determination.

The disclosed schedules have been completed as of 31 January 2022 and, where necessary, forecasted/scaled to reflect the full 2021-22 disclosure year.

**SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE**

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)  
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes).  
 This information is not part of audited disclosure information.

sch ref

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
	for year ended 31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28	31 Mar 29	31 Mar 30	31 Mar 31	31 Mar 32
<b>11a(i): Expenditure on Assets Forecast</b>	<b>\$000 (in nominal dollars)</b>										
Consumer connection	3587	3964	2939	2785	2830	2937	2991	3090	3145	3069	3310
System growth	1122	1970	4549	4159	5825	4539	4259	3118	5370	10704	2862
Asset replacement and renewal	7476	9310	6467	4060	3518	3842	4548	4711	3054	2980	3214
Asset relocations	302	-	-	-	-	-	-	-	-	-	-
Reliability, safety and environment:											
Quality of supply	663	1457	722	622	1034	286	313	436	419	2806	2414
Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment	299	389	178	188	156	162	166	171	174	170	183
<b>Total reliability, safety and environment</b>	<b>962</b>	<b>1845</b>	<b>900</b>	<b>810</b>	<b>1190</b>	<b>449</b>	<b>479</b>	<b>607</b>	<b>593</b>	<b>2976</b>	<b>2597</b>
<b>Expenditure on network assets</b>	<b>13449</b>	<b>17089</b>	<b>14854</b>	<b>11814</b>	<b>13363</b>	<b>11767</b>	<b>12277</b>	<b>11526</b>	<b>12162</b>	<b>19728</b>	<b>11983</b>
Expenditure on non-network assets	721	2150	845	906	896	919	939	996	981	999	1025
<b>Expenditure on assets</b>	<b>14170</b>	<b>19239</b>	<b>15700</b>	<b>12720</b>	<b>14259</b>	<b>12685</b>	<b>13216</b>	<b>12522</b>	<b>13143</b>	<b>20728</b>	<b>13009</b>
plus Cost of financing	-	-	-	-	-	-	-	-	-	-	-
less Value of capital contributions	809	1482	541	271	278	285	291	298	304	311	318
plus Value of vested assets	-	-	-	-	-	-	-	-	-	-	-
<b>Capital expenditure forecast</b>	<b>13361</b>	<b>17757</b>	<b>15158</b>	<b>12449</b>	<b>13981</b>	<b>12401</b>	<b>12925</b>	<b>12224</b>	<b>12839</b>	<b>20417</b>	<b>12691</b>
Assets commissioned	13361	17757	15158	12449	13981	12401	12925	12224	12839	20417	12691
	<b>\$000 (in constant prices)</b>										
Consumer connection	3587	3964	2796	2571	2543	2577	2568	2596	2585	2469	2605
System growth	1122	1970	4328	3838	5234	3984	3657	2620	4415	8610	2253
Asset replacement and renewal	7476	9310	6153	3747	3162	3371	3905	3958	2510	2397	2530
Asset relocations	302	-	-	-	-	-	-	-	-	-	-
Reliability, safety and environment:											
Quality of supply	663	1457	687	574	929	251	269	366	344	2257	1900
Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment	299	389	169	173	140	143	142	144	143	137	144
<b>Total reliability, safety and environment</b>	<b>962</b>	<b>1845</b>	<b>856</b>	<b>748</b>	<b>1069</b>	<b>394</b>	<b>411</b>	<b>510</b>	<b>488</b>	<b>2393</b>	<b>2044</b>
<b>Expenditure on network assets</b>	<b>13449</b>	<b>17089</b>	<b>14133</b>	<b>10903</b>	<b>12008</b>	<b>10326</b>	<b>10542</b>	<b>9684</b>	<b>9998</b>	<b>15869</b>	<b>9432</b>
Expenditure on non-network assets	721	2150	804	836	805	806	806	806	806	804	807
<b>Expenditure on assets</b>	<b>14170</b>	<b>19239</b>	<b>14938</b>	<b>11739</b>	<b>12814</b>	<b>11132</b>	<b>11348</b>	<b>10520</b>	<b>10804</b>	<b>16673</b>	<b>10239</b>
<b>Subcomponents of expenditure on assets (where known)</b>											
Energy efficiency and demand side management, reduction of energy losses	-	108	550	1017	1402	1024	1021	1032	1028	982	1036
Overhead to underground conversion	1698	3709	3264	1755	1191	1197	1551	1438	-	-	-
Research and development	-	-	-	-	-	-	-	-	-	-	-

50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
93  
94  
95  
96  
97  
98  
99  
100  
101  
102  
103  
104

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
for year ended	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28	31 Mar 29	31 Mar 30	31 Mar 31	31 Mar 32
<b>Difference between nominal and constant price forecasts</b>	<b>\$000</b>										
Consumer connection	-	-	143	215	287	360	423	494	560	600	705
System growth	-	-	221	321	591	556	602	498	955	2094	609
Asset replacement and renewal	-	-	314	313	357	470	643	753	543	583	684
Asset relocations	-	-	-	-	-	-	-	-	-	-	-
Reliability, safety and environment:											
Quality of supply	-	-	35	48	105	35	44	70	75	549	514
Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment	-	-	9	14	16	20	23	27	31	33	39
<b>Total reliability, safety and environment</b>	-	-	44	63	121	55	68	97	106	582	553
<b>Expenditure on network assets</b>	-	-	721	911	1355	1441	1735	1842	2164	3859	2552
Expenditure on non-network assets	-	-	41	70	91	112	133	159	175	195	218
<b>Expenditure on assets</b>	-	-	762	981	1446	1553	1868	2001	2338	4055	2770

**11a(ii): Consumer Connection**

Consumer types defined by EDB\*

Urban LV
Urban Transformer
Urban Alteration for Safety (No new ICP created)
Urban Capacity Alteration (No new ICP created)
Rural LV
Rural Transformer
Rural Alteration for Safety (No new ICP created)
Rural Capacity Alteration (No new ICP created)
Other (including large subdivisions)

\$000 (in constant prices)

264	188	191	196	194	197
-	62	63	64	64	65
-	-	-	-	-	-
-	25	25	26	25	26
321	502	510	524	518	527
1067	815	828	850	841	855
209	338	343	341	338	333
191	235	239	241	238	242
1536	1799	598	330	326	332

\*include additional rows if needed

<b>Consumer connection expenditure</b>	3587	3964	2796	2571	2543	2577
less Capital contributions funding consumer connection	783	1184	250	250	250	250
<b>Consumer connection less capital contributions</b>	2804	2780	2546	2321	2293	2327

**11a(iii): System Growth**

Subtransmission	49	85	-	-	12	-
Zone substations	428	90	-	-	1514	369
Distribution and LV lines	127	15	796	164	162	165
Distribution and LV cables	227	429	1041	307	1068	942
Distribution substations and transformers	78	1131	1362	1313	1842	1874
Distribution switchgear	104	5	28	20	321	327
Other network assets	109	216	1101	2034	314	307
<b>System growth expenditure</b>	1122	1970	4328	3838	5234	3984
less Capital contributions funding system growth	18	-	-	-	-	-
<b>System growth less capital contributions</b>	1104	1970	4328	3838	5234	3984

**11a(iv): Asset Replacement and Renewal**

Subtransmission	136	1161	469	-	-	-
Zone substations	12	170	68	70	69	70
Distribution and LV lines	1844	3317	1650	1075	1063	1175
Distribution and LV cables	1700	3360	2926	1667	1111	1154
Distribution substations and transformers	3067	912	724	620	652	699
Distribution switchgear	624	375	304	316	267	273
Other network assets	93	16	13	-	-	-
<b>Asset replacement and renewal expenditure</b>	7476	9310	6153	3747	3162	3371
less Capital contributions funding asset replacement and renewal	8	298	265	-	-	-
<b>Asset replacement and renewal less capital contributions</b>	7468	9012	5888	3747	3162	3371

105  
106  
107  
108  
109  
110  
111  
112  
113  
114  
115  
116  
117  
118  
119  
120  
121  
122  
123  
124  
125  
126  
127  
128  
129  
130  
131  
132  
133  
134  
135  
136  
137  
138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163

Current Year CY  
for year ended 31 Mar 22

CY+1  
31 Mar 23

CY+2  
31 Mar 24

CY+3  
31 Mar 25

CY+4  
31 Mar 26

CY+5  
31 Mar 27

**11a(v): Asset Relocations**

*Project or programme\**

SH1 - Walnut Ave Intersection Redesign
ADC Civic Centre & Library Distribution Substation
Ashburton CBD Duct Network
Rakaia Gorge - 11 kV Metering Point
N/A

\$000 (in constant prices)

98	-	-	-	-	-	-
19	-	-	-	-	-	-
208	-	-	-	-	-	-
(23)	-	-	-	-	-	-
-	-	-	-	-	-	-

*\*include additional rows if needed*

All other project or programmes - asset relocations

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**Asset relocations expenditure**

302	-	-	-	-	-	-
-----	---	---	---	---	---	---

less Capital contributions funding asset relocations

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**Asset relocations less capital contributions**

302	-	-	-	-	-	-
-----	---	---	---	---	---	---

**11a(vi): Quality of Supply**

*Project or programme\**

SCADA - Distribution Automation Programme
ZSS MTV - Reconfiguration
ZSS Upgrading 110VDC Supply
Core Network Centres
22 kV Conversion - Methven Highway Springfield
Rural Ring Main Units
66kV OH Dampers Installation
11kV Core Network Centres
22kV Conversion - Mvn Hwy Sprgfld Rd to Mvn, AF to Nwtns Cnr
22kV OH Reconductor - Coldstream Rd
ZSS EGN - 33kV Ripple Plant Replacement

\$000 (in constant prices)

-	294	299	307	-	-	-
-	-	-	-	-	-	-
55	-	-	-	-	-	-
302	-	-	-	-	-	-
60	-	-	-	-	-	-
92	-	-	-	-	-	-
-	55	-	-	-	-	-
-	542	321	199	465	182	-
-	453	-	-	-	-	-
-	44	-	-	-	-	-
-	-	-	-	396	-	-

*\*include additional rows if needed*

All other projects or programmes - quality of supply

154	70	67	69	68	69	-
-----	----	----	----	----	----	---

**Quality of supply expenditure**

663	1457	687	574	929	251	-
-----	------	-----	-----	-----	-----	---

less Capital contributions funding quality of supply

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**Quality of supply less capital contributions**

663	1457	687	574	929	251	-
-----	------	-----	-----	-----	-----	---

**11a(vii): Legislative and Regulatory**

*Project or programme\**

N/A
N/A
N/A
N/A
N/A

\$000 (in constant prices)

-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-

*\*include additional rows if needed*

All other projects or programmes - legislative and regulatory

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**Legislative and regulatory expenditure**

-	-	-	-	-	-	-
---	---	---	---	---	---	---

less Capital contributions funding legislative and regulatory

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**Legislative and regulatory less capital contributions**

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**11a(viii): Other Reliability, Safety and Environment**

*Project or programme\**

Distribution Earthing Upgrades
ZSS Security and Surveillance Programme
Satellite Comms, NOC/Transpower
Install Transformer Pad in Mt Hutt Zone Substation
N/A

\$000 (in constant prices)

289	80	81	83	82	84	-
-	23	31	32	-	-	-
-	18	-	-	-	-	-
-	212	-	-	-	-	-
-	-	-	-	-	-	-

*\*include additional rows if needed*

All other projects or programmes - other reliability, safety and environment

10	56	57	59	58	59	-
----	----	----	----	----	----	---

**Other reliability, safety and environment expenditure**

299	389	169	173	140	143	-
-----	-----	-----	-----	-----	-----	---

less Capital contributions funding other reliability, safety and environment

-	-	-	-	-	-	-
---	---	---	---	---	---	---

**Other reliability, safety and environment less capital contributions**

299	389	169	173	140	143	-
-----	-----	-----	-----	-----	-----	---

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
for year ended	31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27
<b>11a(ix): Non-Network Assets</b>						
<b>Routine expenditure</b>						
<i>Project or programme*</i>	<b>\$000 (in constant prices)</b>					
Routine Vehicles	-	440	320	320	320	320
Routine Plant	57	90	10	10	10	10
Routine Information Technology	262	370	370	370	370	370
Routine Building Work	-	100	50	50	50	50
Software - GIS Development Programme	-	54	54	56	55	56
Aerial Photography	-	-	-	30	-	-
<i>*include additional rows if needed</i>						
All other projects or programmes - routine expenditure	56	-	-	-	-	-
<b>Routine expenditure</b>	<b>375</b>	<b>1054</b>	<b>804</b>	<b>836</b>	<b>805</b>	<b>806</b>
<b>Atypical expenditure</b>						
<i>Project or programme*</i>						
Buildings - Office Furniture and Fittings	-	39	-	-	-	-
Software	344	-	-	-	-	-
Customer Text Communication	-	70	-	-	-	-
SF6 Analyser	-	43	-	-	-	-
Software - Digitise Work Flows	-	350	-	-	-	-
Software - Integration Application Development	-	180	-	-	-	-
Software - Migration to Cloud	-	75	-	-	-	-
Software - TechOne Development	-	50	-	-	-	-
Solar PV for Corporate Buildings	-	225	-	-	-	-
<i>*include additional rows if needed</i>						
All other projects or programmes - atypical expenditure	2	64	-	-	-	-
<b>Atypical expenditure</b>	<b>346</b>	<b>1096</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>
<b>Expenditure on non-network assets</b>	<b>721</b>	<b>2150</b>	<b>804</b>	<b>836</b>	<b>805</b>	<b>806</b>

**SCHEDULE 11b: REPORT ON FORECAST OPERATIONAL EXPENDITURE**

This schedule requires a breakdown of forecast operational expenditure for the disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. EDBs must provide explanatory comment on the difference between constant price and nominal dollar operational expenditure forecasts in Schedule 14a (Mandatory Explanatory Notes). This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
		for year ended 31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27	31 Mar 28	31 Mar 29	31 Mar 30	31 Mar 31	31 Mar 32
9	<b>Operational Expenditure Forecast</b>	<b>\$000 (in nominal dollars)</b>										
10	Service interruptions and emergencies	1047	1485	1564	1617	1665	1709	1751	1794	1838	1883	1924
11	Vegetation management	539	831	873	901	925	947	968	990	1011	1034	1057
12	Routine and corrective maintenance and inspection	850	1015	1061	1097	1099	1180	1156	1184	1213	1243	1270
13	Asset replacement and renewal	1872	1325	1396	1443	1503	1543	1562	1600	1640	1622	1658
14	<b>Network Opex</b>	4308	4656	4895	5057	5192	5379	5437	5568	5702	5781	5908
15	System operations and network support	4817	5290	5565	5738	5892	6034	6167	6302	6441	6583	6727
16	Business support	5894	7429	7808	8050	8267	8466	8652	8842	9037	9236	9439
17	<b>Non-network opex</b>	10711	12719	13373	13787	14160	14500	14819	15145	15478	15818	16166
18	<b>Operational expenditure</b>	15019	17375	18268	18844	19352	19879	20255	20712	21179	21599	22075
21		<b>\$000 (in constant prices)</b>										
22	Service interruptions and emergencies	1047	1485	1488	1492	1496	1499	1503	1507	1511	1515	1515
23	Vegetation management	539	831	831	831	831	831	831	831	832	832	832
24	Routine and corrective maintenance and inspection	850	1015	1010	1012	988	1035	992	995	997	999	999
25	Asset replacement and renewal	1872	1325	1328	1331	1351	1354	1341	1345	1348	1305	1305
26	<b>Network Opex</b>	4308	4656	4657	4667	4666	4721	4668	4678	4687	4650	4650
27	System operations and network support	4817	5290	5295	5295	5295	5295	5295	5295	5295	5295	5295
28	Business support	5894	7429	7429	7429	7429	7429	7429	7429	7429	7429	7429
29	<b>Non-network opex</b>	10711	12719	12724	12724	12724	12724	12724	12724	12724	12724	12724
30	<b>Operational expenditure</b>	15019	17375	17381	17391	17390	17445	17392	17402	17411	17374	17374
31	<b>Subcomponents of operational expenditure (where known)</b>											
32	Energy efficiency and demand side management, reduction of energy losses	-	-	-	-	-	-	-	-	-	-	-
33	Direct billing*	-	-	-	-	-	-	-	-	-	-	-
34	Research and Development	1	220	220	220	220	220	220	220	220	220	220
35	Insurance	330	341	341	341	341	341	341	341	341	341	341
36												
37	* Direct billing expenditure by suppliers that direct bill the majority of their consumers											
41	<b>Difference between nominal and real forecasts</b>	<b>\$000</b>										
42	Service interruptions and emergencies	-	-	76	125	169	209	247	287	327	368	410
43	Vegetation management	-	-	42	69	94	116	137	158	180	202	225
44	Routine and corrective maintenance and inspection	-	-	51	85	111	144	163	189	216	243	270
45	Asset replacement and renewal	-	-	68	111	152	189	221	256	292	317	353
46	<b>Network Opex</b>	-	-	238	390	526	659	768	890	1014	1131	1258
47	System operations and network support	-	-	270	443	597	739	872	1007	1146	1288	1432
48	Business support	-	-	379	621	838	1037	1223	1413	1608	1807	2010
49	<b>Non-network opex</b>	-	-	649	1063	1436	1776	2095	2421	2754	3094	3442
50	<b>Operational expenditure</b>	-	-	886	1454	1962	2434	2863	3310	3768	4225	4700



Company Name	<b>Electricity Ashburton Limited</b>
AMP Planning Period	<b>1 April 2022 – 31 March 2032</b>

**SCHEDULE 12a: REPORT ON ASSET CONDITION**

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

sch ref	Asset condition at start of planning period (percentage of units by grade)											
	Voltage	Asset category	Asset class	Units	H1	H2	H3	H4	H5	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years
7												
8												
9												
10	All	Overhead Line	Concrete poles / steel structure	No.	-	0.34%	0.43%	69.13%	30.09%	-	2	0.34%
11	All	Overhead Line	Wood poles	No.	1.38%	1.79%	13.01%	39.77%	44.05%	-	2	3.17%
12	All	Overhead Line	Other pole types	No.	-	-	-	75.00%	25.00%	-	2	-
13	HV	Subtransmission Line	Subtransmission OH up to 66kV conductor	km	-	0.24%	2.65%	59.06%	38.06%	-	3	-
14	HV	Subtransmission Line	Subtransmission OH 110kV+ conductor	km	-	-	-	-	-	-	N/A	-
15	HV	Subtransmission Cable	Subtransmission UG up to 66kV (XLPE)	km	-	-	-	16.87%	83.13%	-	3	-
16	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Oil pressurised)	km	-	-	-	-	-	-	N/A	-
17	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Gas pressurised)	km	-	-	-	-	-	-	N/A	-
18	HV	Subtransmission Cable	Subtransmission UG up to 66kV (PILC)	km	-	-	-	-	-	-	N/A	-
19	HV	Subtransmission Cable	Subtransmission UG 110kV+ (XLPE)	km	-	-	-	-	-	-	N/A	-
20	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Oil pressurised)	km	-	-	-	-	-	-	N/A	-
21	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Gas Pressurised)	km	-	-	-	-	-	-	N/A	-
22	HV	Subtransmission Cable	Subtransmission UG 110kV+ (PILC)	km	-	-	-	-	-	-	N/A	-
23	HV	Subtransmission Cable	Subtransmission submarine cable	km	-	-	-	-	-	-	N/A	-
24	HV	Zone substation Buildings	Zone substations up to 66kV	No.	-	4.55%	22.73%	22.73%	50.00%	-	2	-
25	HV	Zone substation Buildings	Zone substations 110kV+	No.	-	-	-	-	-	-	N/A	-
26	HV	Zone substation switchgear	22/33kV CB (Indoor)	No.	-	-	-	-	-	-	N/A	-
27	HV	Zone substation switchgear	22/33kV CB (Outdoor)	No.	-	-	87.50%	12.50%	-	-	3	-
28	HV	Zone substation switchgear	33kV Switch (Ground Mounted)	No.	-	-	-	-	-	-	N/A	-
29	HV	Zone substation switchgear	33kV Switch (Pole Mounted)	No.	-	2.04%	29.93%	47.62%	20.41%	-	3	2.04%
30	HV	Zone substation switchgear	33kV RMU	No.	-	-	-	-	-	-	N/A	-
31	HV	Zone substation switchgear	50/66/110kV CB (Indoor)	No.	-	-	-	-	-	-	N/A	-
32	HV	Zone substation switchgear	50/66/110kV CB (Outdoor)	No.	-	-	30.56%	37.50%	31.94%	-	3	-
33	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (ground mounted)	No.	-	-	5.20%	33.53%	61.27%	-	2	-
34	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (pole mounted)	No.	-	-	-	-	-	-	N/A	-
35												
36												
37												
	Asset condition at start of planning period (percentage of units by grade)											
	Voltage	Asset category	Asset class	Units	H1	H2	H3	H4	H5	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years
38												
39	HV	Zone Substation Transformer	Zone Substation Transformers	No.	-	8.57%	11.43%	31.43%	48.57%	-	3	8.57%
40	HV	Distribution Line	Distribution OH Open Wire Conductor	km	1.31%	3.03%	16.09%	43.86%	35.70%	-	3	4.34%
41	HV	Distribution Line	Distribution OH Aerial Cable Conductor	km	-	-	-	-	-	-	N/A	-
42	HV	Distribution Line	SWER conductor	km	-	-	-	-	-	-	N/A	-
43	HV	Distribution Cable	Distribution UG XLPE or PVC	km	0.01%	0.01%	0.64%	26.06%	73.29%	-	3	0.01%
44	HV	Distribution Cable	Distribution UG PILC	km	-	4.12%	81.04%	14.84%	-	-	1	2.06%
45	HV	Distribution Cable	Distribution Submarine Cable	km	-	-	-	-	-	-	N/A	-
46	HV	Distribution switchgear	3.3/6.6/11/22kV CB (pole mounted) - reclosers and sectionalisers	No.	-	-	30.30%	51.52%	18.18%	-	2	15.00%
47	HV	Distribution switchgear	3.3/6.6/11/22kV CB (Indoor)	No.	-	-	-	-	-	-	N/A	-
48	HV	Distribution switchgear	3.3/6.6/11/22kV Switches and fuses (pole mounted)	No.	0.01%	0.58%	4.24%	36.45%	58.72%	-	2	0.59%
49	HV	Distribution switchgear	3.3/6.6/11/22kV Switch (ground mounted) - except RMU	No.	-	-	-	-	-	-	N/A	-
50	HV	Distribution switchgear	3.3/6.6/11/22kV RMU	No.	4.69%	9.18%	13.28%	30.66%	42.19%	-	3	1.00%
51	HV	Distribution Transformer	Pole Mounted Transformer	No.	0.32%	6.77%	21.94%	27.57%	43.40%	-	3	2.00%
52	HV	Distribution Transformer	Ground Mounted Transformer	No.	0.21%	5.07%	16.81%	19.92%	57.99%	-	3	1.00%
53	HV	Distribution Transformer	Voltage regulators	No.	-	-	100.00%	-	-	-	3	-
54	HV	Distribution Substations	Ground Mounted Substation Housing	No.	2.55%	4.74%	11.31%	26.64%	54.74%	-	2	3.00%
55	LV	LV Line	LV OH Conductor	km	7.93%	11.45%	12.99%	56.73%	10.90%	-	3	19.38%
56	LV	LV Cable	LV UG Cable	km	0.02%	1.34%	6.53%	36.05%	56.07%	-	3	1.36%
57	LV	LV Streetlighting	LV OH/UG Streetlight circuit	km	0.82%	2.46%	7.45%	39.35%	49.91%	-	2	3.28%
58	LV	Connections	OH/UG consumer service connections	No.	-	-	33.33%	33.33%	33.34%	-	3	-
59	All	Protection	Protection relays (electromechanical, solid state and numeric)	No.	-	0.42%	2.94%	1.26%	95.38%	-	2	3.00%
60	All	SCADA and communications	SCADA and communications equipment operating as a single system	Lot	-	-	-	10.00%	90.00%	-	3	25.00%
61	All	Capacitor Banks	Capacitors including controls	No.	-	-	-	-	-	-	N/A	-
62	All	Load Control	Centralised plant	Lot	-	66.67%	33.33%	-	-	-	3	66.67%
63	All	Load Control	Relays	No.	-	-	-	-	-	100.00%	1	-
64	All	Civils	Cable Tunnels	km	-	-	-	-	-	-	N/A	-

**SCHEDULE 12b: REPORT ON FORECAST CAPACITY**

This schedule requires a breakdown of current and forecast capacity and utilisation for each zone substation and current distribution transformer capacity. The data provided should be consistent with the information provided in the AMP. Information provided in this table should relate to the operation of the network in its normal steady state configuration.

sch ref

12b(i): System Growth - Zone Substations									
Existing Zone Substations	Current Peak Load (MVA)	Installed Firm Capacity (MVA)	Security of Supply Classification (type)	Transfer Capacity (MVA)	Utilisation of Installed Firm Capacity %	Installed Firm Capacity +5 years (MVA)	Utilisation of Installed Firm Capacity + 5yrs %	Installed Firm Capacity Constraint +5 years (cause)	Explanation
Ashburton 66/11kV [ASH]	19	22	N-1	20	86%	22	91%	Transformer	Two 20MVA 66/11kV transformers, steady state load transfer to/from NTN, and additional fast transfer switched capacity ensure acceptable security.
Carew 66/22kV [CRW]	15	17	N-1	9	88%	20	75%	No constraint within +5 years	Second transformer is one of two system spares and provides 100% firm capacity. Transfer capacity at 22kV is good.
Coldstream 66/22kV [CSM]	13	-	N	9	-	-	-	Transformer	Second Carew transformer provides an increase in transfer capacity. EFN 22kV conversion improved transfer capacity.
Dorie 66/22kV [DOR]	11	-	N	9	-	-	-	Transformer	Pendarves and Overdale substations offer close to 100% of firm capacity via transfer on 22kV distribution network.
Eiffelton 66/11kV [EFN]	9	-	N	4	-	-	-	Transformer	Transfer capacity has increased significantly with 22kV conversion. Now operating at 66/22kV, all load should be able to be back-fed.
Elgin 66/22kV [EGN] (Future)	-	-	-	-	-	-	-	Transformer	66/33/22kV transformer rated at 20MVA. Will partly unload some 66kV circuits and provide back-feeds at 22kV to other sites. Load secured by existing switched capacity.
Fairton 66/22/11kV [FTN]	8	22	N-1 Switched	11	36%	20	50%	No constraint within +5 years	New substation (2017) with 1x20MVA 66/22kV, 1x20MVA 66/11kV and 1x8MVA 22/11kV transformers. Station firm capacity is enhanced by adjacent switched transfer capacity at 22kV and 11kV.
Hackthorne 66/22kV [HTH]	15	-	N	9	-	-	-	Transformer	Second Carew transformer and 22kV distribution provides extra transfer capacity. 66kV MSM and future MON also significantly increase transfer capacity.
Highbank 66/11kV [HBK]	8	-	N	-	-	-	-	Subtransmission circuit	Owned by Trustpower. Winter: generation. Summer: pump load. By agreement, EA Networks provide N 66kV subtransmission security beyond Methven.
Lagmhor 66/22kV [LGM]	9	-	N	6	-	-	-	Transformer	22kV transfer capacity uses HTH, CRW, and TIN.
Lauriston 66/22kV [LSN]	15	-	N	7	-	-	-	Transformer	Transfer capacity uses 22kV from OVD, FTN, & MTV, larger OVD transformer, and increased MTV 22kV supply capability.
Methven 33/11kV [MVN]	-	-	N	4	-	-	-	No constraint within +5 years	Load transferred to Methven 66/11kV substation in 2016. Acting as hot standby for Methven 11kV load until 2023.
Methven 66/22/11kV [MTV]	5	8	N-1 Switched	5	63%	-	-	Transformer	22/11kV transformer provides significant back-feed from LSN. 66/22kV, 66/11kV & 22/11kV transformers will provide 100% transfer capacity in 2022.
Methven 66/33kV [MTV]	5	-	N	5	-	-	-	No constraint within +5 years	Most 33kV load beyond MTV will be converted to 66/22kV. Mt Hutt 33/11kV load will be supplied by stepping up 22/33kV (2022).
Mt Somers 66/22kV [MSM]	3	5	N-1 Switched	3	58%	-	-	Transformer	66/22kV operation plus conversion of surrounding distribution network to 22kV permits adequate switched transfer capacity. Additional 66kV circuit in 2022 will provide N-1 subtransmission security (currently N subtransmission security).
Mt Hutt 33/11kV [MHT]	2	-	N	2	-	-	-	Transformer	Considered adequate. 33kV and 11kV lines share common poles. Possible 22kV conversion to MTV would increase switched transfer capacity.
Montalto 33/11kV [MON]	2	-	N	1	-	-	-	Transformer	Conversion to 22kV distribution network increases transfer capacity in 2024-25. Redundant as 22kV conversion proceeds.
Northtown 66/11kV [NTN]	14	22	N-1	20	-	20	80%	No constraint within +5 years	Additional 11kV Core Network cables in Ashburton increase fast transfer capacity from ASH.
Overdale 66/22kV [OVD]	14	-	N	10	-	-	-	Transformer	Significant transfer capacity from 66/22kV transformers at adjacent substations ([PDS], [FTN], [DOR], & [LSN]).
Pendarves 66/22kV [PDS]	16	22	N-1	28	73%	20	80%	No constraint within +5 years	Firm capacity limit is N-1 transformer capacity limit plus switched 22kV backfeed. Second transformer is one of two system spares.
Seafield 22/11kV [SFD22]	-	-	N	5	-	-	-	Transformer	Decommissioned as 33/11kV and converted to 22/11kV for 5MVA limited transfer back-up supply to SFD66 (several minutes for restoration).
Seafield 66/11kV [SFD66]	8	5	N-1 Switched	5	160%	-	-	Transformer	Negotiated security with sole industrial customer. A second transformer and short length of 66kV line would provide 100% firm capacity. Remote-controlled change-over between full capacity 66/11kV and adjacent critical load only 22/11kV substations (several minutes).
Wakanui 66/22kV [WNU]	13	-	N	10	-	-	-	Transformer	Elgin's 66/33kV transformer conversion to 66/22kV has increased 22kV fast transfer capacity significantly.

<sup>1</sup> Extend forecast capacity table as necessary to disclose all capacity by each zone substation

## SCHEDULE 12C: REPORT ON FORECAST NETWORK DEMAND

This schedule requires a forecast of new connections (by consumer type), peak demand and energy volumes for the disclosure year and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumptions used in developing the expenditure forecasts in Schedule 11a and Schedule 11b and the capacity and utilisation forecasts in Schedule 12b.

sch ref

### 12c(i): Consumer Connections

Number of ICPs connected in year by consumer type

	Number of connections					
	Current Year CY for year ended 31 Mar 22	CY+1 31 Mar 23	CY+2 31 Mar 24	CY+3 31 Mar 25	CY+4 31 Mar 26	CY+5 31 Mar 27
<i>Consumer types defined by EDB*</i>						
Urban LV	48	45	45	45	45	45
Urban Transformer	7	5	5	5	5	5
Urban Alteration for Safety (No new ICP created)	-	-	-	-	-	-
Urban Capacity Alteration (No new ICP created)	2	5	5	5	5	5
Rural LV	56	60	60	60	60	60
Rural Transformer	60	60	60	60	60	60
Rural Alteration for Safety (No new ICP created)	24	25	25	25	25	25
Rural Capacity Alteration (No new ICP created)	11	15	15	15	15	15
Other	58	60	40	20	20	20
<b>Connections total</b>	<b>266</b>	<b>275</b>	<b>255</b>	<b>235</b>	<b>235</b>	<b>235</b>

\*include additional rows if needed

### Distributed generation

Number of connections

Capacity of distributed generation installed in year (MVA)

	Current Year CY 31 Mar 22	CY+1 31 Mar 23	CY+2 31 Mar 24	CY+3 31 Mar 25	CY+4 31 Mar 26	CY+5 31 Mar 27
Number of connections	55	55	56	56	55	60
Capacity of distributed generation installed in year (MVA)	0	0	50	25	1	1

### 12c(ii) System Demand

#### Maximum coincident system demand (MW)

GXP demand

plus Distributed generation output at HV and above

#### Maximum coincident system demand

less Net transfers to (from) other EDBs at HV and above

#### Demand on system for supply to consumers' connection points

	Current Year CY for year ended 31 Mar 22	CY+1 31 Mar 23	CY+2 31 Mar 24	CY+3 31 Mar 25	CY+4 31 Mar 26	CY+5 31 Mar 27
GXP demand	158	181	184	186	188	190
plus Distributed generation output at HV and above	2	2	2	2	2	2
<b>Maximum coincident system demand</b>	<b>159</b>	<b>183</b>	<b>186</b>	<b>188</b>	<b>190</b>	<b>192</b>
less Net transfers to (from) other EDBs at HV and above	(0)	(0)	(0)	(0)	(0)	(0)
<b>Demand on system for supply to consumers' connection points</b>	<b>159</b>	<b>183</b>	<b>186</b>	<b>188</b>	<b>190</b>	<b>192</b>

#### Electricity volumes carried (GWh)

Electricity supplied from GXPs

less Electricity exports to GXPs

plus Electricity supplied from distributed generation

less Net electricity supplied to (from) other EDBs

#### Electricity entering system for supply to ICPs

less Total energy delivered to ICPs

#### Losses

#### Load factor

#### Loss ratio

	Current Year CY 31 Mar 22	CY+1 31 Mar 23	CY+2 31 Mar 24	CY+3 31 Mar 25	CY+4 31 Mar 26	CY+5 31 Mar 27
Electricity supplied from GXPs	454	508	514	519	524	529
less Electricity exports to GXPs	-	0	0	0	0	0
plus Electricity supplied from distributed generation	144	141	141	141	141	141
less Net electricity supplied to (from) other EDBs	(0)	(0)	(0)	(0)	(0)	(0)
<b>Electricity entering system for supply to ICPs</b>	<b>598</b>	<b>649</b>	<b>654</b>	<b>660</b>	<b>665</b>	<b>670</b>
less Total energy delivered to ICPs	563	607	612	617	622	627
<b>Losses</b>	<b>35</b>	<b>42</b>	<b>42</b>	<b>43</b>	<b>43</b>	<b>43</b>
<b>Load factor</b>	<b>43%</b>	<b>41%</b>	<b>40%</b>	<b>40%</b>	<b>40%</b>	<b>40%</b>
<b>Loss ratio</b>	<b>5.9%</b>	<b>6.5%</b>	<b>6.5%</b>	<b>6.5%</b>	<b>6.5%</b>	<b>6.5%</b>

Company Name	Electricity Ashburton Limited
AMP Planning Period	1 April 2022 – 31 March 2032
Network / Sub-network Name	

### SCHEDULE 12d: REPORT FORECAST INTERRUPTIONS AND DURATION

This schedule requires a forecast of SAIFI and SAIDI for disclosure and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumed impact of planned and unplanned SAIFI and SAIDI on the expenditures forecast provided in Schedule 11a and Schedule 11b.

sch ref		for year ended	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
			31 Mar 22	31 Mar 23	31 Mar 24	31 Mar 25	31 Mar 26	31 Mar 27
8								
9								
10	<b>SAIDI</b>							
11	Class B (planned interruptions on the network)		118.0	120.0	120.0	120.0	120.0	120.0
12	Class C (unplanned interruptions on the network)		137.0	110.0	107.0	100.0	95.0	95.0
13	<b>SAIFI</b>							
14	Class B (planned interruptions on the network)		0.41	0.40	0.40	0.40	0.40	0.40
15	Class C (unplanned interruptions on the network)		1.75	1.25	1.25	1.25	1.25	1.25

## Schedule 14a Mandatory Explanatory Notes on Forecast Information

1. This Schedule requires EDBs to provide explanatory notes to reports prepared in accordance with clause 2.6.6.
2. This Schedule is mandatory—EDBs must provide the explanatory comment specified below, in accordance with clause 2.7.2. This information is not part of the audited disclosure information, and so is not subject to the assurance requirements specified in section 2.8.

### *Commentary on difference between nominal and constant price capital expenditure forecasts (Schedule 11a)*

3. In the box below, comment on the difference between nominal and constant price capital expenditure for the current disclosure year and 10 year planning period, as disclosed in Schedule 11a.

The difference is 0.0% for the 2022-23 year. Costs have been prepared using 2022-23 values for labour, plant, and materials. Years after 2022-23 have been escalated by the "Half Year Economic and Fiscal Update 2021" CPI Forecast by the New Zealand Government Treasury published in December 2021. When the forecast ends, the final year CPI value has been used until the period end.  
( <https://www.treasury.govt.nz/publications/efu/half-year-economic-and-fiscal-update-2021> )

### *Commentary on difference between nominal and constant price operational expenditure forecasts (Schedule 11b)*

4. In the box below, comment on the difference between nominal and constant price operational expenditure for the current disclosure year and 10 year planning period, as disclosed in Schedule 11b.

The difference is 0.0% for the 2022-23 year. Costs have been prepared using 2022-23 values for labour, plant, and materials. Years after 2022-23 have been escalated by the "Half Year Economic and Fiscal Update 2021" CPI Forecast by the New Zealand Government Treasury published in December 2021. When the forecast ends, the final year CPI value has been used until the period end.  
( <https://www.treasury.govt.nz/publications/efu/half-year-economic-and-fiscal-update-2021> )

Financial Year (ending March)	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Treasury CPI Forecast (%)	5.1	3.1	2.7	2.4	2.2	2.2	2.2	2.2	2.2	N/A
Cumulative CPI Price Inflation	1.0000	1.0510	1.0836	1.1128	1.1395	1.1646	1.1902	1.2164	1.2432	1.2705

## Directors' Certification for Year-beginning Disclosures.

### Schedule 17 Certification for Year-beginning Disclosures

#### Clause 2.9.1

We, **Philip John McKendry** and **Paul Jason Munro**, being directors of **Electricity Ashburton Limited** certify that, having made all reasonable enquiry, to the best of our knowledge:

- a) the following attached information of **Electricity Ashburton Limited** prepared for the purposes of clauses 2.6.3, 2.6.6 and 2.7.2 of the Electricity Distribution Information Disclosure Determination 2012 in all material respects complies with that determination.
- b) The prospective financial or non-financial information included in the attached information has been measured on a basis consistent with regulatory requirements or recognised industry standards.
- c) The forecasts in Schedules 11a, 11b, 12a, 12b, 12c and 12d are based on objective and reasonable assumptions which both align with **Electricity Ashburton Limited's** corporate vision and strategy and are documented in retained records.



**Philip John McKendry**



**Paul Jason Munro**

**31 March 2022.**



